Compliance Report

Simmons (972) 342-3094
Statistical Inventory Reconciliation
COMPLIANCE REPORT
01-18-2000 - 10:32:06

Company : AIMS DEMO COMPANY Location: STATION #312
Tank ID : 01 312 01
Period : 12/18/99 - 01/17/00

Dates	Sales	Receipts	Book	Closing Stick	Daily O/S	Cumulative O/S
12/18/99	1500.0	8300.0		9685.0		
12/19/99	1250.0	0.0	8435.0	8430.0	-5.0	-5.0
12/20/99	1150.0	0.0	7280.0	7279.0	-1.0	-6.0
12/21/99	1160.0	0.0	6119.0	6121.0	2.0	-4.0
12/22/99	1305.0	4500.0	9316.0	9324.0	8.0	4.0
12/23/99	1100.0	0.0	8224.0	8237.0	13.0	17.0
12/24/99	1151.0	0.0	7086.0	7082.0	-4.0	13.0
12/25/99	1200.0	0.0	5882.0	5894.0	12.0	25.0
12/26/99	1565.0	0.0	4329.0	4314.0	-15.0	10.0
12/27/99	1152.0	0.0	3162.0	3157.0	-5.0	5.0
12/28/99	1300.0	0.0	1857.0	1855.0	-2.0	3.0
12/29/99	1540.0	8300.0	8615.0	8617.0	2.0	5.0
12/30/99	1612.0	0.0	7005.0	7009.0	4.0	9.0
01/01/00	500.0	0.0	6509.0	6514.0	5.0	14.0
01/02/00	595.0	0.0	5919.0	5913.0	-6.0	8.0
01/03/00	1150.0	0.0	4763.0	4752.0	-11.0	-3.0
01/04/00	1160.0	0.0	3592.0	3600.0	8.0	5.0
01/05/00	1030.0	5100.0	7670.0	7666.0	-4.0	1.0
01/06/00	1100.0	0.0	6566.0	6569.0	3.0	4.0
01/07/00	1151.0	0.0	5418.0	5420.0	2.0	6.0
01/08/00	1200.0	3000.0	7220.0	7226.0	6.0	12.0
01/09/00	1565.0	0.0	5661.0	5648.0	-13.0	-1.0
01/10/00	1152.0	0.0	4496.0	4504.0	8.0	7.0
01/11/00	1300.0	0.0	3204.0	3194.0	-10.0	-3.0
01/12/00	2000.0	8500.0	9694.0	9706.0	12.0	9.0
01/13/00	1612.0	0.0	8094.0	8106.0	12.0	21.0
01/14/00	1200.0	0.0	6906.0	6900.0	-6.0	15.0
01/15/00	1155.0	0.0	5745.0	5743.0	-2.0	13.0
01/16/00	1255.0	0.0	4488.0	4485.0	-3.0	10.0
01/17/00	1600.0	0.0	2885.0	2886.0	1.0	11.0

Number of Days Submitted: 30 Absolute Average O/S : 6.2
Minimum Daily Sales : 500.0 Minimum Product in Tank: 1,855.0
Maximum Daily Sales : 2,000.0 Maximum Product in Tank: 9,706.0
Average Daily Sales : 1,257.0 Number of Deliveries : 6
Total Product Sold : 37,710.0 Total Product Delivered: 37,700.0

INVENTORY CONTROL STATUS: PASS

TANK & LINES: PASS LEAK RATE: 0.012 MDL: 1.023 THR: 1.00

AUTO*SIR*'s Compliance Report meets the latest EPA standards, showing the minimum detectable leak rate (MDL), the estimated leak rate and the threshold. This tool provides insights beyond just the simple PASS or FAIL. How bad does a leak appear to be? The estimated leak rate tells you; it prints on the compliance reports. How good is your data? The minimum detectable leak rate tells you; it reports the smallest leak detectable, given the quality of your data. For **AUTO*SIR,*** which uses Simmons' SIR software, its false alarm "threshold" has always been 1% (the EPA allows no more than a 5% false alarm probability).